

**PUBLIC NOTICE MANDATORY LANGUAGE CODING  
Tier 2 violations/ Non-Acute**

**Mandatory Language for Surface Water Treatment Technique Violation**

**SURFACE WATER TREATMENT TECHNIQUE: [NON-ACUTE]**

The Texas Commission on Environmental Quality (TCEQ) sets minimum water quality standards for public drinking water. These standards include enforceable treatment technique requirements for drinking water. Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.

The City of Point PWS ID TX1900004 failed to meet the minimum treatment technique requirements for the month of May 2023. Specifically, our water system had

- Combined filter effluent turbidity readings above 1.0 NTU.

If you have questions regarding this matter, you may contact Matthew Collins at (903)474-3028.

Posted /Delivered on:

8/01/2023  
<Date Posted>

---