

**Public Notice Mandatory Language for Monitoring and Reporting Violation  
Operational Evaluation Report**

The City of Point water system PWS ID TX1900004 has violated the monitoring and reporting requirements set by Texas Commission on Environmental Quality (TCEQ) in Chapter 30, Section 290, Subchapter F. Public water systems in exceedance of an operational evaluation level are required to conduct an evaluation of their source water, treatment and distribution operations and submit a report of their findings to the TCEQ.

We failed to conduct an operational evaluation and/or submit a report to the TCEQ.

This/These violation(s) occurred in the monitoring period(s) 4Q2021.

**We are taking the following actions to address this issue:**

**Operator training was provided through the TCEQ DAM classes. A new CT study was conducted and approved by TCEQ. The LAS injection point has been moved from downstream of the chlorine injection to upstream of the chlorine injection. A new operator obtained the C surface water license**

Please share this information with all other people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact Matthew Collins at (903)-474-3028

Posted/Delivered on: 4/15/2024

---