



Public Drinking Water Violation Report

Operators are to complete this form to report violations in public drinking water treatment at facilities that provide treatment for surface water or groundwater under the direct influence of surface water. This form is not to be used to report to the public.

System Information

Public Water System Name: City of Point
 PWS ID #: TX1900004
 Treatment Plant Name or Number: Point water treatment plant
 Operator Name: Matthew Collins
 Operator Signature: *Matthew Collins*
 Date Signed: 05/26/2023.
 Operator Telephone Number.: 903-474-3028

Violation Information

Type of Violation(s): turbidity Between 1.0 NTU and 5.0 NTU (e.g., turbidity above 5.0 NTU, turbidity between 1.0 NTU and 5.0 NTU, turbidity above 0.3 NTU, low CT value, low residual leaving the plant, low distribution system residual, ClO2 residual above 0.8 mg/L, in distribution, failed to achieve Crypto credit required, etc.)
 Date/Time that the violation was detected: 05/26/2023 at 0836
 Duration of the Violation (if known): 14.5 hours (i.e., 5 hours, 1 day, 2 months)
 Describe corrective action taken including dates: reprimed coagulant pump, backwashed filter, and backflushed clarifier.

Other Data, for SWTPs only

Finished Water Turbidity (in NTU) [DURING THE EVENT]: 4.39 NTU
 Highest IFE Turbidity Level (in NTU) [DURING THE EVENT]: 6.64 NTU
 Giardia Inactivation (log) [DURING THE EVENT]: 5.44
 Viral Inactivation (log) [DURING THE EVENT]: 13.03

Submit Completed Form

Please note that email often is the fastest, most reliable method of communicating a violation.

- Email to: SWTR@tceq.texas.gov
- Mail to: SWTR Coordinator, MC-155, PO BOX 13087, Austin, TX 78711